

AS SHOWN

HEIGHT DATUM- AHD

150

CONSTRUCTION

PRELIMINARY - FOR REVIEW AND COMMENT ONLY

AMENDMENT DETAILS

11.06.13

14.12.12

DATE

A3 ORIGINAL THIS SHEET WAS PREPARED IN COLOUR AND WILL BE INCOMPLETE IF COPIED COORDINATE SYSTEM:

J.C.

INITIALS

900

150

NOTES

- 1. ALL DIMENSIONS ARE IN MILLIMETRES.
- 2. DRAWING NOT TO SCALE.
- 3. PITS DEEPER THAN 1200 TO BE FITTED WITH STEP IRONS AT 300 CENTRES TO AS1657
- 4. CONCRETE FOR UNREINFORCED PITS:
- 25 MPa GRADE N25:80:10 IN ACCORDANCE WITH AS1379 AND AS3600. CONCRETE FOR REINFORCED PITS:
- 32 MPa GRADE N32:80:10 IN ACCORDANCE WITH AS1379 AND AS3600.
- 5. STEEL REINFORCING BARS AND FABRIC TO COMPLY WITH AS/NZS4671 GRADE D500N
- 6. FOR DETAILS OF CONCRETE AND STEEL REINFORCEMENT FOR PITS GREATER THAN 1.5 METERS IN DEPTH SEE TABLE A.
- 7. 100 DIAMETER SUBSOIL DRAINAGE PIPE 3000 LONG WRAPPED IN FABRIC SOCK WITH END CAP TO BE PROVIDED ADJACENT TO INLET PIPES.
- 8. POSITION ENTRY AND HINGES TO BEST SUIT SITE CONSTRAINTS AND POSITIONING OF STEP IRONS.
- 9. DIMENSION 'D' TO BE MINIMUM OF I.D. +300. PIT TYPE JP4 MAY BE UTILIZED WHEN
- D > 1.5 METRES.

DATE:...

J.C.

REVIEWED:

- 10. CONCRETE FINISHES:
- ALL PEDESTRIAN OR TRAFFICABLE AREAS TO BE NON-SLIP WOOD FLOAT OR BROOM FINISH WITH ALL EXPOSED EDGES ROUNDED TO 5 RADIUS. OTHER EXPOSED SURFACES TO BE OFF STEEL FORM QUALITY.
- 11. FOUNDING MATERIAL TO ACHIEVE A MINIMUM ALLOWABLE BEARING CAPACITY OF 150KPa

TABLE A: SCHEDULE OF TRAFFICABLE PITS				
'H' MAX DEPTH (M)	'L'&'B' MAX WIDTH/LENGTH (M)	SECTION	CONCRETE GRADE	CONSTRUCTION METHOD
1.2	1.2	150 THICK WALLS UNREINFORCED	25MPa	INTERNAL FORMWORK ONLY WITH HAND VIBRATION
1.5	1.2	150 THICK WALLS UNREINFORCED	25MPa	INTERNAL AND EXTERNAL WALL FORMWORK WITH MECHANICAL VIBRATION
3.5	1.6	150 THICK WALLS REINFORCED AS DETAILED BELOW	32MPa	INTERNAL AND EXTERNAL WALL FORMWORK WITH MECHANICAL VIBRATION

REINFORCEMENT DETAILS: SL92 FABRIC CENTRAL OR N12-200 B/WAYS. HORIZONTAL BARS TO BE CENTRALLY PLACED. RETURN STEEL INTO BASE BY 200 MIN. PROVIDE 200 MIN. LAP AT WALL/WALL CORNERS PROVIDE 50 MIN COVER TO REINFORCEMENT

APPROVED:	THE CITY OF NEWCASTLE		
SIGNED:INFRASTRUCTURE MANAGEMENT SERVICES MANAGER	JUNCTION PIT WITH SQUARE CAST IRON ACCESS COVER TYPE JP3		

NCC PLAN No.

A2101

AMENDMENT No.

SHEET No.

0F

SHEETS